

SECTION 3

3.01 GENERAL:

Water is conveyed from mains to Customers by service lines and their appurtenances. In the context of these Standards, service lines include all pipe and fittings up to and including the stop and waste valve in the residence for outside meter settings, and up to and including the valve at the downstream side of the meter for inside settings as shown on Sheets 48 and 50 of the Standard Drawings. All water pipe beyond service lines shall be controlled by the local plumbing codes.

All new or replacement service lines and appurtenant fittings installed in areas being supplied with potable water from Denver Water shall conform to the following minimum standards which shall be binding regardless of the regulations of any other agency covering like installations.

The corporation stop, the meter, and that portion of the service line between the meter and the corporation stop and 5 feet past the meter shall all be of the same size. From this point through the inside valve, service lines may be increased one pipe size.